Quasi Steady-State Frequency

Joan Gutiérrez-Florensa, Student, IEEE, Álvaro Ortega, Member, IEEE, Lukas Sigrist, Member, IEEE, and Federico Milano, Fellow, IEEE

Abstract—Accurate frequency estimation is critical for the control, monitoring and protection of electrical power systems, in particular, of systems with a high penetration of power electronics. This paper introduces the novel concept of Quasi Steady-State (QSS) frequency as a quantity that fills the gap between stationary and instantaneous frequency. QSS frequency coincides with the fundamental frequency of an AC voltage in any stationary conditions, including umbalanced and nonsinusoidal, and is able to capture the time-varying fundamental frequency in transient conditions. The paper also proposes a metric borrowed from fluid dynamics, namely, the time derivative of the circulation, to define the scope of validity of the OSS frequency. Analytical examples as well as a case study based on a fully-fledged EMT model of the IEEE 39-bus system serve to illustrate, respectively, the properties of the QSS frequency and its behavior in transient conditions.

Index Terms—Frequency measurement, filtering, differential geometry, instantaneous frequency, Fourier transform.

I. INTRODUCTION

A. Motivation

The meaning of frequency in transient conditions have been widely discussed in the literature, and how to properly define it is still an open question. The core of the problem is that, on the one hand, frequency is well defined only for a periodic stationary signal (let us call it Fourier frequency). On the other hand, in power system applications, such as active power control, the estimation of frequency is required during a transient for which the measured signal, typically the voltage at a relevant bus, is not stationary. The quantity that is usually estimated in transient conditions is known as instantaneous frequency [1]. Fourier and instantaneous frequencies coincide only in stationary conditions. During transients and other common operating conditions such as stationary unbalanced and non-sinusoidal, these two quantities not only do not coincide but give rise to inconsistencies so hard to explain that have been described as "paradoxes" [2]. In turn, Fourier and instantaneous frequencies may be treated as two different quantities, and the one that most closely aligns with measurements depends on the specific nature of the application [3]. This paper proposes a novel quantity, namely, the QSS frequency, that fills the gap between Fourier and instantaneous frequencies.

Á. Ortega and L. Sigrist are with School of Engineering, Comillas Pontifical University, 28015, Madrid, Spain. e-mails: {aortega, lsigrist}@comillas.edu

This work is supported by the Sustainable Energy Authority of Ireland (SEAI) under project FRESLIPS, Grant No. RDD/00681.

B. Literature Review

There exists several approaches to estimate frequency during electrical transients. These include, among others, Phase-Locked Loops (PLLs), [4], [5], discrete Fourier transform, [6], [7], [8], Kalman filters, [9], [10], least squares, [11], [12], and adaptive notch filters, [13], [14]. PLLs are a common solution for grid synchronization and frequency control, whereas Fourier-based methods are generally employed in monitoring and state-estimation. The working principle of PLLs is to estimate the instantaneous frequency through the definition of two voltage components, typically in the dq-axis reference frame. Fourier-based methods define a mobile window and assume the signal to be periodic. Both approaches have issues.

The estimation of the instantaneous frequency by means of PLLs shows the issues of any control loop, that is, the better the noise is filtered, the higher the delay with which the signal is estimated. A tradeoff is thus needed. Moreover, the estimation based on PLLs is biased by the well-known issue of showing spikes in correspondence of abrupt events occurring in the system. Figure 1 illustrates this situation by comparing the frequency estimated with a PLL at the terminal bus of a synchronous machine with the rotor speed of the machine itself. The spikes appear in the PLL estimation after a fault and after the line trip that clears the fault. However, the rotor speed is smooth and does not show spikes. It is thus legitimate to wonder whether the spikes represent a physical variation of the frequency or a mere limitation of the PLL. This is also still an open question.



Fig. 1: Difference between rotor speed and the frequency at the terminal bus of synchronous machine during a transient following a short circuit and its clearance close to the machine.

Fourier-based approaches are generally based on the fast discrete version of the Fourier transform. These approaches work because, even if the fundamental frequency is not perfectly constant, it never varies too much in power systems, and a window of 20 ms for systems at 50 Hz (16.7 ms for systems at 60 Hz) provides a reasonable representation of the

J. Gutiérrez-Florensa and F. Milano are with the School of Elec. & Electron. Eng., University College Dublin, Dublin, D04V1W8, Ireland. e-mails: joan.gutierrezflorensa1@ucdconnect.ie, federico.milano@ucd.ie,

signal. However, the window creates several problems, such as aliasing and spectral leakage, which, ultimately, cannot be completely solved.

The coexistence of several approaches to estimate the frequency indicates that no approach is a clear winner. In [15], various conventional and experimental frequency measurement methods are tested for a variety of robust-demanding situations according to the standard in [1] and the tests proposed in [16]. The conclusion is that no approach is able to satisfy all the tests but each one can be suggested for different use cases. Most of these methods use filters or correctors to reduce the measurement oscillations and, in some cases, they return different results for the same case. This suggests that more research has to be done. In particular, we believe that a key aspect of most unresolved issues are the conceptual differences between Fourier and instantaneous frequency.

In [17], the authors try to conciliate the inconsistencies and paradoxes of Fourier and instantaneous frequencies through a geometrical approach, which identifies the instantaneous frequency as the curvature of an abstract trajectory, where the measured voltage take the meaning of a "velocity" [18]. The main conclusion of this interpretation is that the instantaneous frequency is a geometric invariant, that is, a quantity the value of which does not change no matter the coordinates (measurements) that are utilized [19]. Being an invariant, the instantaneous frequency is always "right." On the other hand, the Fourier frequency is a coordinate without any special geometrical meaning except for the case of a stationary sinusoidal balanced voltage. This conclusion is not fully satisfactory, as the instantaneous frequency is not always the quantity that one expects to obtain, specifically, in non-sinusoidal or imbalanced stationary signals [20].

In summary, the Fourier frequency can in principle be defined only in ideal stationary conditions, but intuitively represents what one would expect to be the fundamental frequency of a signal that is "almost" stationary after removing all harmonics and unbalances. On the other hand, the instantaneous frequency is always valid and its meaning can be rigorously shown to be a precise geometric quantity but often lacks an intuitive meaning and can be deceiving in simple situations such as, for example, a stationary voltage with a small negative sequence component.

Recently, the last author of this work proposed a breakdown of the geometrical frequency into terms that are commonly utilized in fluid dynamics, namely, a vorticity, a time-dependent term, and a distortion (strain) term [21]. The vorticity is proportional to the part of the velocity of a fluid line that represents a rigid-body rotation. In this paper, we show that the vorticity is the term that contains the intuitive information of fundamental frequency of a non-stationary signal.

C. Contributions

This paper proposes a novel quantity, namely the Quasi Steady-State (QSS) frequency, which aims at filling the conceptual gap between the Fourier and the instantaneous frequencies. The theoretical foundation of the definition of QSS frequency is based on a theorem by Cauchy on vorticity [22]. The QSS is valid in transients, but retains the intuitive meaning of a "slowly" changing fundamental frequency, and it is constant (in fact, equal to the fundamental frequency) for a stationary voltage, even if it is not balanced or sinusoidal.

Additionally, the QSS frequency comes with an embedded metric, formally the time derivative of the circulation, which we duly define in the remainder of the paper. This metric allows establishing the threshold of validity of the estimation, since the QSS frequency cannot be "always" determined. Rather, it is defined only if the time derivative of the circulation is below a given threshold. In turn, the proposed metric clarifies whether the spikes observed for the instantaneous frequency (see Fig. 1) are physical or numerical and allows defining in a precise analytical way what parts of the trajectory of the QSS frequency during a power system transient retain the meaning of a slowly-varying fundamental frequency.

D. Paper Organization

This paper is organized as follows. Section II recalls relevant concepts from geometric frequency and frequency decomposition from Lagrange derivative equivalence. This section provides the background for the subsequent developments in this work. Section III includes the formulation and formal definition of QSS frequency. Section IV introduces the time derivative of circulation and the proposed use as a metric to determine the existence of a fundamental frequency. Section V presents a variety of analytical and numerical examples that illustrate the proposed QSS frequency and metric. Section VI examines the behavior of the proposed quantities in a set of case studies. Section VII provides concluding remarks. Finally, conclusions and future work are given in Section VIII.

E. Notation

Scalar quantities are represented by italic font, e.g., a or A, vectors by bold lower case, e.g., a, tensors and matrices by bold upper case, e.g., A. The transpose of a vector a is denoted with a^T and the time derivative of a quantity a is indicated with a'. Unless indicated otherwise, quantities are assumed to be time dependent.

II. BACKGROUND

This section recalls the definitions of relevant quantities that are utilized in developments of the paper. These key concepts include *geometric frequency* and *vorticity* as a component of the geometric frequency.

Consider the magnetic flux, φ , as a three-dimensional space curve. Its dynamics are described by:

$$\varphi' = \upsilon, \qquad (1)$$

where v is the voltage vector.

Its arc length, s, and curvature, κ , are defined as [23]:

$$s = \int_0^t \sqrt{\varphi' \cdot \varphi'} \, d\tau = \int_0^t |\boldsymbol{v}| \, d\tau \,, \tag{2}$$

$$\kappa = \frac{|\varphi' \times \varphi''|}{|\varphi'|^3} = \frac{|\upsilon \times \upsilon'|}{|\upsilon|^3} \,. \tag{3}$$

The skew-symmetrical part of the geometric frequency is defined as:

$$\boldsymbol{\omega}_{\boldsymbol{v}} = \frac{\boldsymbol{v} \times \boldsymbol{v}'}{|\boldsymbol{v}|^2}, \qquad (4)$$

where $|\omega_v| = \kappa |v|$ is an estimation of the instantaneous frequency of the voltage [18]. Equation (4) indicates that ω_v can be calculated exclusively based on voltage measurements.

Let us now assume that $\omega_{\upsilon} = \omega_{\upsilon}(t, \varphi)$. Then, ω_{υ} can be shown to be composed of various terms with precise physical meanings borrowed from fluid dynamics, as follows [21]:

$$\omega_{\upsilon} = \frac{\upsilon \times \partial_t \upsilon}{|\upsilon|^2} + \frac{\upsilon \times (R\upsilon)}{|\upsilon|^2} + \frac{1}{2} (\nabla \times \upsilon)$$

= $\omega_t + \omega_r + \frac{1}{2} \mathbf{w}$, (5)

where ∂_t indicates the partial derivative with respect to time; ω_t is related to the non-stationary conditions of the voltage; ω_r is related to the voltage "distortion," characterized by matrix \mathbf{R} ; and \mathbf{w} is the vorticity, given by the curl ($\nabla \times$) of the voltage and represents the rotation of a rigid body. The details of the steps required to obtain the terms that appear in (5) are given in Appendix A.

In stationary conditions, i.e. $\partial_t v = \mathbf{0}_3$, and no distortion, i.e. $\mathbf{R} = \mathbf{0}_{3,3}$, the instantaneous frequency is given by:

$$\boldsymbol{\omega}_{\boldsymbol{\upsilon}} = \frac{1}{2} (\nabla \times \boldsymbol{\upsilon}) = \frac{1}{2} \mathbf{w}.$$
 (6)

Reference [21] also shows that vorticity is constant in all stationary cases and it is proportional to the fundamental frequency. In this scenario the voltage trajectory rotates constantly at the fundamental frequency forming a perfect circle (that is, a curve with constant curvature κ) every period (see gray lines in Fig. 2a).

For an unbalanced, non-sinusoidal or transient voltages, ω_r and/or ω_t are not zero and the trajectory is not a circle anymore (see Fig. 2).



Fig. 2: Comparison of voltage trajectories of (a) a sinusoidal unbalanced voltage signal, and (b) a non-sinusoidal balanced voltage signal with respect of a sinusoidal balanced voltage signal (gray line).

Regardless the presence of harmonics or unbalances, the vorticity always represents the actual inherent rotation of the system that does not depend on the operating conditions. However, according to (5), to calculate the vorticity, one needs to calculate $\nabla \times v$. This implies the knowledge of the dependence of the velocity (voltage) with respect to the position (fluxes), namely of the expression $v(t, \varphi)$. In practice, this function

is not available and cannot be determined based on the sole measurements of v. In order to overcome this problem, in the following section, we leverage a theorem developed by Cauchy, which relates the vorticity with the average rotation. This theorem permits avoiding calculating $\nabla \times v$.

III. DEFINITION OF QUASI-STEADY STATE FREQUENCY

In [22], Cauchy developed a theorem that relates vorticity with average rotation, as follows:

$$\frac{1}{2\pi} \int_0^{2\pi} \boldsymbol{\omega}_{\boldsymbol{\upsilon}}(\delta) \, d\delta = \frac{1}{2} (\nabla \times \boldsymbol{\upsilon}) = \frac{1}{2} \mathbf{w} \,, \tag{7}$$

where the left-hand term represents the average of the instantaneous rotation all over a closed line ℓ along a line of flow (see Fig. 3) and the right-hand term is half of the vorticity. Note that (6) represents a special case of (7), that is, the case for which ω_v is a constant vector and, hence its average along ℓ coincides with it is punctual value.



Fig. 3: Representation of the Cauchy's theorem that relates vorticity and the average of the angular speed, ω_v , along the surface A, whose perimeter is the closed line ℓ , for a point over a fluid line with velocity v. Note that theorem applies for any arbitrary closed line.

We now have a relationship between ω_v and w that does no involves ω_r and ω_t . However, we have shifted the problem to calculate w to the problem of calculating the integral of ω_v with respect to the spatial angle δ along ℓ . The next step is to find a way to calculate the left-hand side of (7) with the quantities that can be actually measured or estimated, which are all function of time.

With this aim, we note that Cauchy's theorem is relevant for closed space curves that fulfill:

$$\kappa_{\rm T} = \oint_{\ell} \kappa(s) \, ds = 2\pi \,, \tag{8}$$

where κ_{T} is the total curvature. This requirement is the condition for a space curve to be a Jordan's curve, i.e. a simple closed curve [23]. From arc length, curvature and geometric frequency definitions, in (2), (3) and (4) respectively, (8) can be rewritten as:

$$\kappa_{\mathrm{T}} = \oint_{T} \kappa |\boldsymbol{v}| \, d\tau = \oint_{T} \frac{|\boldsymbol{v} \times \boldsymbol{v}'|}{|\boldsymbol{v}|^2} \, d\tau = \oint_{T} |\boldsymbol{\omega}_{\boldsymbol{v}}| \, d\tau \,, \qquad (9)$$

and equaling (8) with (9), we obtain:

$$\oint_T |\boldsymbol{\omega}_{\boldsymbol{v}}| \, d\tau = 2\pi \,. \tag{10}$$

Equation (10) not only gives a condition for a space curve to be a Jordan's curve but it also provides a geometrical definition of the period, T, of a signal. If the trajectory of a dynamical system generates a Jordan's curve, there exists an associated period defined as the time that it takes, for a given initial condition at time t_0 , to close the trajectory curve:

$$T = \inf\left\{t: t > t_0, \int_{t_0}^{t+t_0} |\boldsymbol{\omega}_{\boldsymbol{v}}| \, d\tau = 2\pi\right\}$$
(11)

The information obtained with (11) is twofold. On the one hand, if the curve is closed, one can define its equivalent period T and the existence of the period implies the existence of an associated frequency. On the other hand, if the trajectory is not closed, the period and thus the frequency cannot be defined. Equation (11) is key for the developments of this work because: (i) it provides a way to obtain the period T through the evaluation of the instantaneous frequency; and (ii) it can be calculated only with voltage measurements.

It is important to note that the mere existence of a period does not imply the applicability of Cauchy's theorem. If the curve is a closed curve with double points, it has an associated period but it is beyond the Jordan's curves. Hence, the Cauchy's theorem is not directly applicable and the associated period cannot be measured through the condition in (9). This issue is further discussed in Section V-D.

Once the period is evaluated with (11), the average of the instantaneous rotation can be redefined in time-domain in the Cauchy's theorem, in the form of (7), leading to the proposed definition of QSS frequency, hereinafter indicated with ω_{QSS} :

$$\boldsymbol{\omega}_{\text{QSS}} = \frac{1}{T} \oint_{T} \boldsymbol{\omega}_{\boldsymbol{\upsilon}} \, d\tau \tag{12}$$

The integral that appears in (12) effectively operates averaging out the distortions (ω_r) and time-varying components (ω_t) that are included in the instantaneous frequency. What remains after the calculation of (12) is the sought fundamental frequency of the measured signal. Note that ω_{QSS} is time varying if the period T is time varying.

IV. TIME DERIVATIVE OF CIRCULATION AS A PERIODICITY CONDITION

In the previous section, it has been assumed that the trajectory along which v is calculated forms a Jordan's curve. In this section, we provide a metric, independent from the condition in (11), to determine if this assumption is satisfied. For this purpose, we utilize the concept of circulation along a smooth closed curve ℓ that was originally introduced for the study of fluid dynamics [24]. Let Γ be the circulation, then using once again the analogy between an electrical voltage and a velocity, one has:

$$\Gamma = \oint_{\ell} \boldsymbol{v} \, ds \,. \tag{13}$$

Then, applying Stokes' theorem, which relates the line integral of a vector to the surface integral of its curl [25], the circulation can be written as:

$$\Gamma = \oint_{\ell} \boldsymbol{\upsilon} \, ds = \int_{A} (\nabla \times \boldsymbol{\upsilon}) \, dA = \int_{A} \mathbf{w} \, dA \,, \qquad (14)$$

where A is an open surface bounded by ℓ and the right-hand term is defined as the flux of the vorticity [26].

Next, we use Green's theorem, which states that, given two functions, p(x, y) and q(x, y), with continuous partial derivatives, the following identity holds [27]:

$$\oint_{\ell} (\mathbf{p}dx + \mathbf{q}dy) = \int_{A} \left(\frac{\partial \mathbf{p}}{\partial x} - \frac{\partial \mathbf{q}}{\partial y}\right) dA.$$
(15)

Green's theorem refers to a two dimensions, i.e., vorticity is defined in the normal direction with respect of the (x, y) plane. In three or more dimensions, the theorem can generally be applied to each combination of two coordinates separately.

In the electric domain, by choosing $p = v_{\alpha}(\varphi_{\alpha}, \varphi_{\beta})$ and $q = v_{\beta}(\varphi_{\alpha}, \varphi_{\beta})$, the left-hand term of (15) is rewritten as:

$$\oint_{\ell} (\upsilon_{\alpha} d\varphi_{\alpha} + \upsilon_{\beta} d\varphi_{\beta}) = \oint_{T} (\upsilon_{\alpha} \upsilon_{\alpha} d\tau + \upsilon_{\beta} \upsilon_{\beta} d\tau) = \oint_{T} |\boldsymbol{v}|^{2} d\tau.$$
(16)

Then, using (15), given the left-hand term defined in (16), in equation (14), the circulation is obtained as:

$$\Gamma = \oint_{T} |\boldsymbol{v}|^{2} d\tau = \int_{A} \left(\frac{\partial v_{\alpha}}{\partial \varphi_{\alpha}} - \frac{\partial v_{\beta}}{\partial \varphi_{\beta}} \right) dA$$

$$= \int_{A} \mathbf{w} \cdot dA.$$
(17)

We now use Kelvin's circulation theorem that states that the rate of change of circulation around a closed contour is zero [26]. Applying this theorem to (17), the condition for a signal to represent a closed trajectory is:

$$\Gamma' = \oint_T (|\boldsymbol{v}|^2)' \, d\tau = 0 \,. \tag{18}$$

The time derivative of the circulation allows determining if the curve is periodic and, consequently, whether frequency can be defined. Thus, we propose to use (18) as a metric to evaluate the scope of validity of the QSS frequency.

In practice, it is not possible to obtain exactly zero, even if the signal is in effect periodic, due to measurement and numerical errors. We propose thus to use a threshold, say ϵ , and argue that the QSS frequency has the meaning of "fundamental frequency" if:

$$\Gamma' = \oint_T (|\boldsymbol{v}|^2)' \, d\tau < \epsilon \tag{19}$$

While in principle arbitrary, the choice of ϵ is quite straightforward as Γ' is very small if the curve is periodic and increases quickly as periodicity is lost. We duly illustrate this point in the case study discussed in Section VI.

V. ILLUSTRATIVE EXAMPLES

To provide a clearer understanding of the presented concepts of QSS frequency and time-derivative of circulation, in this section, we present various analytical and numerical examples.

A. Stationary balanced sinusoidal voltage

Under stationary and balanced conditions, the voltage components of a three-phase system, in the $\alpha\beta\gamma$ stationary frame, are given by:

$$\boldsymbol{v} = (v_{\alpha}, v_{\beta}, v_{\gamma})^T = (V \cos \theta, V \sin \theta, 0)^T$$

being its magnitude:

$$|\boldsymbol{v}| = \sqrt{\boldsymbol{v} \cdot \boldsymbol{v}} = \sqrt{V^2 \left(\cos^2 \theta + \sin^2 \theta\right)} = V,$$

and its time derivative:

$$\boldsymbol{v}' = \omega_o (-V\sin\theta, V\cos\theta, 0)^T$$

where $\theta = \omega_o t + \phi$ for a given initial shift ϕ .

The instantaneous frequency, calculated with (4), is:

$$\boldsymbol{\omega}_{\boldsymbol{\upsilon}} = \frac{\omega_o}{V^2} \begin{pmatrix} V \cos \theta \\ V \sin \theta \\ 0 \end{pmatrix} \times \begin{pmatrix} -V \sin \theta \\ V \cos \theta \\ 0 \end{pmatrix} = \omega_o \boldsymbol{e}_{\gamma}$$

where $e_{\gamma} = [0, 0, 1]^T$. From the Jordan's curve condition in (9), the period of the signal can be calculated from the following identity:

$$\kappa_{\mathrm{T}} = \oint_{T} |\boldsymbol{\omega}_{\boldsymbol{\upsilon}}| \, d\tau = \int_{0}^{T} \omega_{o} \, d\tau = \omega_{o} T = 2\pi \, .$$

From which, according to the definition in (11), the period will be equal to $T = 2\pi/\omega_o$. Once the period is obtained, the QSS frequency can be calculated as follows:

$$\boldsymbol{\omega}_{\text{QSS}} = \frac{1}{T} \oint_{T} \boldsymbol{\omega}_{\boldsymbol{\upsilon}} d\tau$$
$$= \frac{\omega_{o}}{2\pi} \int_{0}^{T} \omega_{o} \boldsymbol{e}_{\gamma} d\tau = \frac{\omega_{o}^{2}}{2\pi} T \boldsymbol{e}_{\gamma} = \omega_{o} \boldsymbol{e}_{\gamma} .$$

As expected, if voltage is balanced, sinusoidal and stationary, the instantaneous frequency and the magnitude of the QSS frequency is equal to the fundamental frequency of the voltage, namely ω_o . Then, the time derivative of the circulation gives:

$$\Gamma' = |\boldsymbol{v}(T)| - |\boldsymbol{v}(0)| = V - V = 0$$

which confirms that the voltage is periodic and ω_{QSS} is well defined.

B. DC voltage

From a geometric perspective, the trajectory of a DC voltage is defined by a straight line, or equivalently, a line with zero total curvature. Consequently, the associated period tends to infinity as, theoretically, it will take an infinite amount of time for the total curvature to reach the value of 2π . Thus, the QSS frequency and, equivalently, the local rigid body rotation are null. This conclusion matches the results in [21] where DC voltage is described as an irrotational field.

C. Stationary unbalanced sinusoidal voltage

Consider the following unbalanced voltage in $\alpha\beta\gamma$ coordinates:

$$\boldsymbol{v} = (v_{\alpha}, v_{\beta}, v_{\gamma})^{T} = (V_{\alpha} \cos \theta, V_{\beta} \sin \theta, 0)^{T},$$

with time derivative:

$$\boldsymbol{v}' = \omega_o (-V_\alpha \sin \theta, V_\beta \cos \theta, 0)^T$$

The instantaneous frequency measured with the geometric definition is:

$$\boldsymbol{\omega}_{\boldsymbol{\upsilon}} = \frac{\omega_o V_\alpha V_\beta}{|\boldsymbol{\upsilon}|^2} \boldsymbol{e}_{\gamma} = \frac{\omega_o V_\alpha V_\beta}{V_\alpha^2 \cos^2 \theta + V_\beta^2 \sin^2 \theta} \boldsymbol{e}_{\gamma}$$

The period can be easily obtained with (11). However, for illustration, we use instead the calculation of the total arc length:

$$s_{\rm T} = s(T) - s(0) = \oint_{T} |\boldsymbol{v}| d\tau$$

$$= \int_{0}^{T} \sqrt{V_{\alpha}^{2} \cos^{2}\theta + V_{\beta}^{2} \sin^{2}\theta} d\tau$$

$$= \int_{0}^{T} \sqrt{V_{\alpha}^{2} (1 - \sin^{2}\theta) + V_{\beta}^{2} \sin^{2}\theta} d\tau$$

$$= V_{\alpha} \int_{0}^{T} \sqrt{1 - \left(1 - \frac{V_{\beta}^{2}}{V_{\alpha}^{2}}\right) \sin^{2}\theta} d\tau$$

$$= \frac{V_{\alpha}}{\omega_{o}} \int_{0}^{\omega_{o}T} \sqrt{1 - \left(1 - \frac{V_{\beta}^{2}}{V_{\alpha}^{2}}\right) \sin^{2}\theta} d\theta$$

$$= \frac{V_{\alpha}}{\omega_{o}} \mathcal{E} \left(\omega_{o}T | 1 - \frac{V_{\beta}^{2}}{V_{\alpha}^{2}}\right),$$
(20)

where \mathcal{E} is used to represent the Legendre elliptic integral of the second kind of the variable x, given a parameter k, defined as $\mathcal{E}(x|k) = \int (1 - k \sin^2 x)^{1/2} dx$ [28].

It is well-known that the perimeter of an ellipse, which is the total arc length over the closed curve, is given by [29]:

$$s_{\mathrm{T}} = a\mathcal{E}(2\pi|e^2) = a\mathcal{E}\left(2\pi|1 - \frac{b^2}{a^2}\right),\tag{21}$$

where a and b are the semimajor and semiminor axes, respectively, and e is the eccentricity.

Comparison of (20) with (21) proves that the trajectory of the voltages defines an ellipse parameterized by $a = V_{\alpha}/\omega_o$ and $b = V_{\beta}/\omega_o$. Moreover, the comparison of the angle of both expressions shows that the period that "closes" the ellipse is $T = 2\pi/\omega$.

Given the period, the QSS frequency is:

$$\boldsymbol{\omega}_{\text{QSS}} = \frac{1}{T} \int_{0}^{T} |\boldsymbol{\omega}_{\boldsymbol{v}}| \boldsymbol{e}_{\gamma} \, d\tau$$
$$= \frac{1}{T} \boldsymbol{e}_{\gamma} \tan^{-1} \left(\frac{V_{\beta} \sin (\omega_{o}T)}{V_{\alpha} \cos (\omega_{o}T)} \right)$$
$$= \frac{1}{T} \boldsymbol{e}_{\gamma} \tan^{-1} \left(\frac{V_{\beta} \sin (2\pi)}{V_{\alpha} \cos (2\pi)} \right) = \frac{2\pi}{T} \boldsymbol{e}_{\gamma} = \omega_{o} \boldsymbol{e}_{\gamma} \, .$$

This result shows that an unbalance in the voltage components causes the instantaneous frequency measurement to oscillate. In contrast, the QSS frequency removes these oscillations and provides the actual fundamental frequency of the voltage.

The Jordan's curve condition is verified with (18) as follows:

$$\Gamma' = |\boldsymbol{v}(T)|^2 - |\boldsymbol{v}(0)|^2 = V_{\alpha}^2 \left(\cos^2 \left(2\pi + \phi\right) - \cos^2 \left(\phi\right)\right) + V_{\beta}^2 \left(\sin^2 \left(2\pi + \phi\right) - \sin^2 \left(\phi\right)\right) = 0$$

This identity states that any unbalanced sine wave voltage system describes a Jordan's curve every period T.

For illustration, $|\omega_{\upsilon}|$, $|\omega_{QSS}|$ and Γ' , for an amplitude unbalance of $V_{\alpha} = 1.5V_{\beta}$, are shown in Fig. 4.

The measured instantaneous frequency oscillates, forming a distorted sine shape. The oscillations are visibly not symmetric with respect of the fundamental frequency. However,



Fig. 4: Stationary unbalanced sinusoidal AC voltage results for instantaneous frequency, QSS frequency and time derivative of circulation.

the periods of the lower-amplitude oscillations are longer than the higher-amplitude oscillations, balancing the variations and resulting in an average value equal to the fundamental frequency.

For the same study case, in [21], a different reference frame is used, leading to a different value of the vorticity. The intrinsic selection of reference frame of the QSS frequency measurement, ensures that the reference frame is such that the relative component of the frequency is zero. Note that the choice of a reference frame with this property is not unique. However, despite the dependence of the vorticity on the reference frame, the approach proposed in this paper guarantees the reliability of the measured QSS frequency as it is measured from the geometric invariant, ω_v , and the geometric period that is intrinsically related to this invariant.

D. Stationary balanced non-sinusoidal voltage

The case of the stationary balanced voltages described by a non-sinusoidal are here studied through the example of the addition of one harmonic of order h and magnitude V_h . The voltages in the $\alpha\beta\gamma$ frame are:

$$\boldsymbol{\upsilon} = (\upsilon_{\alpha}, \upsilon_{\beta}, \upsilon_{\gamma})^{T} = \begin{pmatrix} V \cos \theta + V_{h} \cos \theta_{h} \\ V \sin \theta + V_{h} \sin \theta_{h} \\ 0 \end{pmatrix}, \qquad (22)$$

where $\theta_h = h\omega_o t + \phi_h$ for a given initial shift ϕ_h . The time derivative of the voltage is:

$$\boldsymbol{v}' = \omega_o \left(-V \sin \theta - h V_h \sin \theta_h, V \cos \theta + h V_h \cos \theta_h, 0 \right)^T,$$

and the instantaneous frequency is:

$$\boldsymbol{\omega}_{\boldsymbol{\upsilon}} = \omega_o \frac{V^2 + hV_h^2 + (1+h)VV_h \cos\left(\theta - \theta_h\right)}{V^2 + V_h^2 + VV_h \cos\left(\theta - \theta_h\right)} \boldsymbol{e}_{\gamma}.$$

$$\begin{split} s_{\rm T} &= \oint_{T} |\boldsymbol{v}| \, d\tau \\ &= \int_{0}^{T} \sqrt{V^2 + V_h^2 + VV_h \cos\left(\theta - \theta_h\right)} \, d\tau \\ &= -\frac{2\sqrt{V^2 + V_h^2 + VV_h}}{(h-1)\omega_o} \mathcal{E}\left(\frac{(1-h)}{2}\omega_o T \mid \frac{2VV_h}{V^2 + V_h^2 + VV_h}\right) \\ &= \frac{\sqrt{V^2 + V_h^2 + VV_h}}{\omega_o} \mathcal{E}\left(\omega_o T \mid \frac{2VV_h}{V^2 + V_h^2 + VV_h}\right) \\ &= \frac{\sqrt{V^2 + V_h^2 + VV_h}}{\omega_o} \mathcal{E}\left(\omega_o T \mid 1 - \frac{V^2 + V_h^2 - VV_h}{V^2 + V_h^2 + VV_h}\right). \end{split}$$

Then, the trajectory can be characterized as an equivalent ellipse parameterized by $a = (V^2 + V_h^2 + VV_h)^{1/2} /\omega_o$ and $b = (V^2 + V_h^2 - VV_h)^{1/2} /\omega_o$. According to the definition of the perimeter of an ellipse in (21), the period is proved to be $T = 2\pi/\omega_o$. Interestingly, while the parametrization of the ellipse is arbitrary, the results obtained with the original proposed formulation are not.

The time derivative of the circulation proves that the trajectory defines a Jordan's curve as follows:

$$\Gamma' = |\upsilon(T)|^2 - |\upsilon(0)|^2 =$$

= $VV_h \left(\cos \left(2\pi (h-1) + \phi - \phi_h \right) - \cos \left(\phi - \phi_h \right) \right) = 0,$

as long as h is an integer.

As the trajectory is proved to define a Jordan's curve, the identity in (8) holds and, hence, the QSS frequency can be simply calculated as:

$$\boldsymbol{\omega}_{\text{QSS}} = \frac{1}{T} \boldsymbol{e}_{\gamma} \oint_{T} |\boldsymbol{\omega}_{\boldsymbol{v}}| \, d\tau = \frac{2\pi}{T} \boldsymbol{e}_{\gamma} = \omega_{o} \boldsymbol{e}_{\gamma}$$

This result verifies the capacity of the QSS frequency on clearing the oscillating terms from the harmonics of the instantaneous frequency and provide the actual periodicity of the signal.

We illustrate the analytical results above with a numerical example. The studied case considered harmonics orders $h = \{7, 11\}$ with amplitudes of $V_h = \{5.83\%, 3.71\%\}$ and phase angles of $\phi_h = \{210^\circ, 330^\circ\}$. The results are displayed in Fig. 5.

Non-sinusoidal voltages allow discussing the case of close curves that are not Jordan's curves. If the harmonic level is high enough, in fact, the trajectory may present *crunodes*, i.e. ordinary double points, before completing a period of the fundamental frequency. This situation is shown in Fig. 6 considering the harmonic h = 7 with amplitude of $V_h = 55.83\%$ and phase angles of $\phi_h = 210^\circ$.

From a geometric perspective, harmonics represent a sequence of punctual deformations over the sinusoidal voltage trajectory defined by a circle if balanced or an ellipse if unbalanced. In this scenario, the period, by definition, is not unique and the algorithm will measure the first one. Consequently, the time derivative of circulation condition in (18) will not validate the physical existence of this measured period as a Jordan's curve period.



Fig. 5: Stationary balanced non-sinusoidal AC voltage results for instantaneous frequency, QSS frequency and time derivative of circulation.



Fig. 6: Stationary balanced non-sinusoidal AC voltage trajectory with the presence of high-level harmonics.

While the theoretical possibility of the existence of crunodes complicates the application of the approach proposed in this paper, we note that, from a practical point of view, the appearance of crunodes in the trajectory of a voltage measured in real-world power systems is highly unlikely. For example, Standard IEEE 519 specifies that the acceptable individual voltage distortion for each harmonic is below the 5% [30]. In order to produce crunodes, for harmonics with this magnitude, the order of the harmonic has to be quite high, namely $h \ge 20$. The interested reader can find a geometrical justification of this condition in Appendix B. In practice, harmonics of this order are filtered and their amplitude is well below 5%.

VI. CASE STUDIES

In this section, we discuss the estimation of the QSS frequency and the time derivative of the circulation as obtained during power system transients. We also compare the QSS frequency with the frequency estimation obtained with a conventional PLL.

The assessed model is the IEEE 39-bus system provided with DIgSILENT PowerFactory software tool. Details on this systems and its set up can be found in in [17]. The results are measured at bus 26 and come from EMT simulation, with a sample time of 10^{-5} s, under a secured three-phase fault

PLL frequency (ω_{PLL}), QSS frequency (ω_{QSS}) and time derivative of circulation (Γ') are obtained for the following scenarios:

- Balanced operation (Figs. 7a and 7b).
- Balanced operation with Gaussian noise in the voltage measurement (Figs. 7c and 7d).
- Unbalanced operation (Figs. 7e and 7f).
- Unbalanced 5th and 7th harmonics current source addition at bus 26 (Figs. 7g and 7h).

Results indicate that the QSS frequency is consistent with the PLL estimation after the clearance of the fault, but it does not introduce a delay. For balanced operation, no oscillations are produced in the instantaneous frequency measurement, and thus, both frequency results coincide before and after the occurrence of the fault. For the scenarios with unbalanced and harmonics, on the other hand, the QSS frequency is capable of averaging out the oscillations of the instantaneous frequency and provide the fundamental frequency associated to the periodicity.

The assessment of the time derivative of the circulation provides a deeper understanding of the nature of these results. As mentioned in Section IV, in order to evaluate this parameter, when working with discrete data, it is necessary to define a threshold that defines the interval within which the gap between the initial and the final point is small enough to be considered a closed curve.

By looking at the results of the balanced case under steadystate, we have set $\epsilon = 10^{-2}$ pu as the threshold to decide if a curve is closed or not. Figures 7b, 7d, 7f and 7h show that the results for all scenarios lead to the same conclusion, as follows. The measured values before and after the fault are below this threshold and, hence, prove that the trajectories can be defined by a Jordan's curve with a periodicity defined by the corresponding QSS frequency measurement. On the other hand, during the fault – grey-shaded area in the figures – the time derivative of the circulation indicates that the trajectories, for the corresponding measured period, define an open curve.

Finally, numerical aspects of the evaluation of the time derivative of the circulation are discussed. As it is to be expected, its accuracy relies on the sampling rate of the measurements and the numerical methods utilized to calculate derivatives and integrals, as well as to filter the noise. However, based on several tests that have been carried out, it is observed that Γ' tends to change abruptly and of various orders of magnitude when the signal ceases to be periodic, whereas it tends to remain "small" when QSS conditions are satisfied. For example, Fig. 8 illustrates the effect of different sampling times on the evaluation of Γ' in steady state conditions for the unbalanced case of the IEEE 39-bus systems discussed above. Despite the sampling time changes of 2 orders of magnitude, Γ' remains well below the threshold utilized to decide whether the signal is periodic.



Fig. 7: Frequency and time derivative of the circulation of the voltage at bus 26 of the IEEE 39-bus model following a three-phase fault and its clearance after 100 ms: (a, b) balanced operation; (c, d) balanced operation with noise; (e, f) unbalanced operation; and (g, h) unbalanced harmonics current source.

VII. REMARKS

The following remarks are relevant.

- Analytical and numerical results validate the analytical findings from section III and IV. The QSS frequency measurement, based on this theoretical framework, is proved to be reliable on averaging out the instantaneous frequency oscillations.
- The time derivative of circulation proves to be a consistent metric on verifying the periodicity of the signal and, consequently, the physical relevance of the frequency results. In order to provide reliable information, for prac-



Fig. 8: Time derivative of circulation of the unbalanced scenario under steady-state operation from 0.05 s to 0.15 s for a sample time of (a) 10^{-5} s, and (b) 10^{-3} s.

tical applications, it is necessary to define an appropriate threshold value with respect of the sample time of the measurements.

- If periodicity exists, the QSS frequency measurement provides a value that accurately represents this periodicity through its fundamental period and frequency.
- From the geometric definition of the period, an associated period does not exist for DC voltage and for extreme AC voltage transient periods (e.g., during a fault).
- With high harmonic distortion, the existence of the period might not be unique as the trajectory might represent multiple closed curves.

VIII. CONCLUSIONS

This paper defines the novel concept of QSS frequency. This quantity fills the conceptual gap between stationary and instantaneous frequency. On the one hand, it does not require perfect stationary conditions and can be measured at any scenario. On the other hand, it provides meaningful information regarding the nature of the signal's periodicity, if such periodicity exists.

To endow this frequency quantity with a formal analytical meaning, this paper also introduces the time derivative of circulation as a metric that determines the existence of periodicity and, consequently, of a fundamental frequency. This condition can be determined based solely on voltage measurements.

The natural extension of this work is the testing of the QSS frequency and the time derivative of circulation metric in realworld applications and the comparison of the performance of electric systems with respect to other frequency measurements available in literature. Future research will also explore the relation between the sample time of measurements and the necessary threshold to define this metric. Finally, the potential of this metric as a technique to detect operational conditions, e.g., the presence of infra-harmonics, will be further investigated.

Appendix A

LAGRANGE DERIVATIVE

In this appendix, part of the theory established in [21] about geometric frequency decomposition from Lagrange derivative equivalence is recalled to provide supplementary materials that support the here presented theory. The Lagrange derivative for a given quantity, in this case v, is defined as:

$$\boldsymbol{v}' = \partial_t \boldsymbol{v} + \boldsymbol{v} \left(\boldsymbol{v} \cdot \nabla \right) \,. \tag{23}$$

From the triple cross product identity:

$$a \times (b \times c) = b(a \cdot c) - c(a \cdot b)$$

the definition in (23) can be rewritten, by identifying a = c = vand $b = \nabla$, as:

$$oldsymbol{v}' = \partial_t oldsymbol{v} + rac{1}{2}
abla (oldsymbol{v} \cdot oldsymbol{v}) - oldsymbol{v} imes (
abla imes oldsymbol{v})$$

 $= \partial_t oldsymbol{v} + rac{1}{2}
abla |oldsymbol{v}|^2 + (
abla imes oldsymbol{v}) imes oldsymbol{v}$.

The latter two terms can be rewritten by the Jacobian of the voltage, $J = v\nabla$, as follows:

$$\frac{1}{2}\nabla|\boldsymbol{v}|^2 = (\nabla\boldsymbol{v})\boldsymbol{v} = \boldsymbol{J}^T\boldsymbol{v},$$
$$(\nabla\times\boldsymbol{v})\times\boldsymbol{v} = (\boldsymbol{J}-\boldsymbol{J}^T)\boldsymbol{v}.$$

The Lagrange derivative, in terms of J, is defined by:

$$\boldsymbol{\upsilon}' = \partial_t \boldsymbol{\upsilon} + \boldsymbol{J}^T \boldsymbol{\upsilon} + (\boldsymbol{J} - \boldsymbol{J}^T) \boldsymbol{\upsilon}$$
$$= \partial_t \boldsymbol{\upsilon} + \boldsymbol{J} \boldsymbol{\upsilon} .$$

The Jacobian of the voltage, as a square matrix, can be decomposed, from the Toeplitz transformation, into a symmetric matrix, D, and a skew-symmetric matrix, Q:

$$J = \frac{1}{2}(J + J^{T}) + \frac{1}{2}(J - J^{T}) = D + Q$$

Both matrices are tensors that represent different kind of dynamics. The symmetric matrix, D, represents a pure strain motion, whereas the skew-symmetric matrix, Q, represents the rigid-body angular rotation.

The pure strain tensor can be further decomposed into two symmetric matrices by:

$$D = S + R$$
,

where R is the shear strain tensor and S is the normal strain tensor defined by the trace of J:

$$\boldsymbol{S} = \frac{1}{n} \operatorname{tr}(\boldsymbol{J}) \boldsymbol{I}_n = \nabla \cdot \boldsymbol{v},$$

where n is the dimension of the voltage vector and I_n is the identity matrix of order n. The presented decomposition of J leads to the expression in (5).

Finally, the Lagrange derivative can be rewritten, in terms of the presented tensors, as follows:

$$\boldsymbol{v}' = \partial_t \boldsymbol{v} + \boldsymbol{S}\boldsymbol{v} + \boldsymbol{R}\boldsymbol{v} + \boldsymbol{Q}\boldsymbol{v}$$

= $\partial_t \boldsymbol{v} + (\nabla \cdot \boldsymbol{v})\boldsymbol{v} + \boldsymbol{R}\boldsymbol{v} + \frac{1}{2}(\nabla \times \boldsymbol{v}) \times \boldsymbol{v}.$ (24)

In order to make the equivalence between the Lagrange derivative and the rotation component of the geometric frequency, the expression in (24) is substituted in the definition in (4). Identifying that $\boldsymbol{\upsilon} \times (\nabla \cdot \boldsymbol{\upsilon})\boldsymbol{\upsilon} = (\nabla \cdot \boldsymbol{\upsilon})(\boldsymbol{\upsilon} \times \boldsymbol{\upsilon}) = \mathbf{0}$, the rotation $\boldsymbol{\omega}_{\boldsymbol{\upsilon}}$ can be expressed by:

$$\boldsymbol{\omega}_{\boldsymbol{\upsilon}} = \frac{\boldsymbol{\upsilon} \times \boldsymbol{\upsilon}'}{|\boldsymbol{\upsilon}|^2} = \frac{\boldsymbol{\upsilon} \times \partial_t \boldsymbol{\upsilon}}{|\boldsymbol{\upsilon}|^2} + \frac{\boldsymbol{\upsilon} \times (\boldsymbol{R}\boldsymbol{\upsilon})}{|\boldsymbol{\upsilon}|^2} + \frac{1}{2} (\nabla \times \boldsymbol{\upsilon}),$$

justifying the expression presented in (5).

APPENDIX B

CRUNODES IN HARMONIC VOLTAGE TRAJECTORIES

The trajectory of balanced voltages containing one harmonic can be geometrically constructed as an *epitrochoid*.

An epitrochoid is a curve traced by a point, P, connected to a circle, with radius r, rolling on the exterior of a circumference of another circle with radius R [31]. Its parametric equations are defined as follows:

$$\begin{pmatrix} x \\ y \end{pmatrix} = \begin{pmatrix} (R+r)\cos\theta - d\cos\left(\frac{R+r}{r}\theta\right) \\ (R+r)\sin\theta - d\sin\left(\frac{R+r}{r}\theta\right) \end{pmatrix}$$

where d is the distance between P and the center of the circle with radius r.

Identifying $x = v_{\alpha}$ and $y = v_{\beta}$, the epitrochoid can be parametrized, from the voltage definition in (22), as follows:

$$d = V_h, \qquad r = \frac{V}{h}, \qquad R = V\left(1 - \frac{1}{h}\right). \tag{25}$$

Note that the sign of the right-hand term of the parametric equations is changed. This implies a shift on the direction of the rotation but does not change the traced trajectory.

By the assessment of the voltage time derivative, it is remarkable that $v'_{\alpha} = v'_{\beta} = 0$ when $\theta = 2n\pi/(h-1)$. This implies that, if h is an integer, there are n = (h-1) inner loops and critical points every period such that $\Delta \theta = 2\pi$.

Epitrochoids can be classified in three different types, *curtates* if d < r, *epicycloids* if d = r and *prolates* if d > r [32]. In Fig. 9 a detailed view of different voltage trajectories for different values of d are shown.



Fig. 9: Detailed view of different trajectories of the voltage system in (22) for different values of V_h such that trace different types of epitrochoids, $V_h = d_P$ for a prolate, $V_h = d_C$ for a curate, and $V_h = d_E$ for an epicycloid.

For the critical points to be crunodes, the distance d needs to be long enough to produce a loop, meaning the epitrochoid needs to be of the last type.

Considering a set of balanced voltages with one harmonic, the prolate condition can be rewritten, using the parametrization in (25), as:

$$\frac{V_h}{V} > \frac{1}{h} \, .$$

For example, given the edge case of $V_h/V = 5\%$ specified in the standard [30], this condition proves that the harmonic order needs to be $h \ge 20$ to form crunodes.

REFERENCES

- "IEEE/IEC International Standard Measuring Relays and Protection Equipment - Part 118-1: Synchrophasor for Power Systems - Measurements," *IEC/IEEE Std.* 60255-118-1:2018, pp. 1–78, 2018.
- [2] L. Cohen, Time-frequency analysis. Prentice Hall, 1995, vol. 778.
- [3] L. Mandel, "Interpretation of instantaneous frequencies," American Journal of Physics, vol. 42, no. 10, pp. 840–846, 10 1974.
- [4] B. Liu, F. Zhuo, Y. Zhu, H. Yi, and F. Wang, "A three-phase PLL algorithm based on signal reforming under distorted grid conditions," *IEEE Trans. on Power Electronics*, vol. 30, no. 9, pp. 5272–5283, 2014.
- [5] M. Eskandari and A. V. Savkin, "Robust PLL synchronization unit for grid-feeding converters in micro/weak grids," *IEEE Trans. on Ind. Informatics*, vol. 19, no. 4, pp. 5400–5411, 2022.
- [6] D. Agrez, "Weighted multipoint interpolated DFT to improve amplitude estimation of multifrequency signal," *IEEE Trans. on Instr. and Meas.*, vol. 51, no. 2, pp. 287–292, 2002.
- [7] P. Romano, M. Paolone, J. Arnold, and R. Piacentini, "An interpolated-DFT synchrophasor estimation algorithm and its implementation in an FPGA-based PMU prototype," in *IEEE PES General Meeting*. IEEE, 2013, pp. 1–6.
- [8] J. Song, A. Mingotti, J. Zhang, L. Peretto, and H. Wen, "Fast iterativeinterpolated DFT phasor estimator considering out-of-band interference," *IEEE Trans. on Instr. and Meas.*, vol. 71, pp. 1–14, 2022.
- [9] S. Reza, M. Ciobotaru, and V. G. Agelidis, "Accurate estimation of single-phase grid voltage fundamental amplitude and frequency by using a frequency adaptive linear Kalman filter," *IEEE J. of Emerging and Selected Topics in Power Elec.*, vol. 4, no. 4, pp. 1226–1235, 2016.
- [10] X. Nie, "Detection of grid voltage fundamental and harmonic components using Kalman filter based on dynamic tracking model," *IEEE Trans. on Ind. Electronics*, vol. 67, no. 2, pp. 1191–1200, 2019.
- [11] S. Giarnetti, F. Leccese, and M. Caciotta, "Non recursive multi-harmonic least squares fitting for grid frequency estimation," *Measurement*, vol. 66, pp. 229–237, 2015.
- [12] A. Pradhan, A. Routray, and A. Basak, "Power system frequency estimation using least mean square technique," *IEEE Trans. on Power Delivery*, vol. 20, no. 3, pp. 1812–1816, 2005.
- [13] F. Wilches-Bernal, J. Wold, and W. H. Balliet, "A method for correcting frequency estimates for synthetic inertia control," *IEEE Access*, vol. 8, pp. 229 141–229 151, 2020.
- [14] M. Mojiri, M. Karimi-Ghartemani, and A. Bakhshai, "Estimation of power system frequency using an adaptive notch filter," *IEEE Trans. on Instr. and Meas.*, vol. 56, no. 6, pp. 2470–2477, 2007.
- [15] J. Ting, B. Wang, R. W. Kenyon, and A. Hoke, "Evaluating methods for measuring grid frequency in low-inertia power systems," in 2022 IEEE Kansas Power and Energy Conference (KPEC), 2022, pp. 1–6.
- [16] G. Rietveld, P. S. Wright, and A. J. Roscoe, "Reliable rate-of-change-offrequency measurements: Use cases and test conditions," *IEEE Trans. on Instr. and Meas.*, vol. 69, no. 9, pp. 6657–6666, 2020.
- [17] F. Milano et al., "Using differential geometry to revisit the paradoxes of the instantaneous frequency," *IEEE Open Access Journal of Power* and Energy, vol. 9, pp. 501–513, 2022.
- [18] F. Milano, "A geometrical interpretation of frequency," *IEEE Trans. on Power Systems*, vol. 37, no. 1, pp. 816–819, 2021.
- [19] F. Milano, G. Tzounas, I. Dassios, and T. Kerci, "Applications of the Frenet frame to electric circuits," *IEEE Trans. on Circuits and Systems I: Regular Papers*, vol. 69, no. 4, pp. 1668–1680, 2021.
- [20] A. Alshawabkeh, G. Tzounas, Á. Molina-García, and F. Milano, "Instantaneous frequency estimation in unbalanced systems using affine differential geometry," *IEEE Trans. on Circuits and Systems II: Express Briefs*, vol. 72, no. 1, pp. 343–347, 2025.
- [21] F. Milano, "Equivalence between geometric frequency and Lagrange derivative," *IEEE Trans. on Circuits and Systems I: Regular Papers*, pp. 1–10, 2024.
- [22] A. L. Cauchy, Mémoire sur les dilatations, les condensations et les rotations produits par un changement de forme dans un système de points matériels. Cambridge University Press (in French), 2009, vol. 12, pp. 343–377, originally published in 1841.
- [23] J. J. Stoker, Differential Geometry. John Wiley & Sons, Ltd, 1969.
- [24] A. J. Chorin, The Equations of Motion. Springer, 1994, pp. 5-24.
- [25] T. Kambe, Flows of ideal fluids. World Scientific, 2007, pp. 77-113.
- [26] P. K. Kundu and I. M. Cohen, *Fluid Mechanics*, 2nd ed. Academic Press, 2002.
- [27] K. Riley, M. Hobson, and S. Bence, *Mathematical Methods for Physics and Engineering*. Cambridge University Press, 2006.

- [28] I. Gradshteyn and I. Ryzhik, *Table of Integrals, Series, and Products*, 7th ed., A. Jeffrey, D. Zwillinger, I. Gradshteyn, and I. Ryzhik, Eds. Boston: Academic Press, 2007.
- [29] P. Abbott, "On the perimeter of an ellipse," *The Mathematica Journal*, vol. 11, no. 2, pp. 172–185, 2009.
- [30] "IEEE Standard for Harmonic Control in Electric Power Systems," *IEEE Std 519-2022 (Revision of IEEE Std 519-2014)*, pp. 1–31, 2022.
- [31] G. Salmon, A treatise on the higher plane curves: intended as a sequel to A treatise on conic sections. Hodges, Foster, and Figgis, 1879.
- [32] S. Hotton, "A geometric invariant for the study of planar curves and its application to spiral tip meander," *arXiv*:1602.07758, 2016.



Joan Gutiérrez-Florensa received the B.Sc. degree in Electrical Engineering from Universitat Politècnica de Catalunya in 2022. He received the joint M.Sc. degree from Hochschule für Technik und Wirtschaft Berlin, Germay, and École Centrale de Nantes, France, as part of a multi-institutional master's program. He is currently pursuing a joint Ph.D. in Electrical Engineering at University College Dublin, Ireland, and Universidad Pontificia Comillas, Spain. His research interests include power system modeling, control and stability analysis.



Álvaro Ortega received the Graduate degree from The Higher Technical School of Industrial Engineering, University of Castilla, La Mancha, Spain, in 2013, and the Ph.D. degree in electrical engineering from University College Dublin, Ireland, in 2017. He has been an Assistant Professor in power and energy systems with the ICAI School of Engineering, Comillas Pontifical University, since September 2021. Previously, he was with LOYOLATech, University Loyola Andalucia, and with the School of Electrical and Electronic Engineering, University

College Dublin. His current research interests include modeling, control and stability of energy storage systems connected to transmission and distribution systems, frequency estimation, control, and stability in low-inertia systems.



Lukas Sigrist received the M.Sc. degree in electrical and electronics engineering from the École Polytechnique Fédérale de Lausanne (EPFL), Switzerland, in 2007, and the Ph.D. degree from the Universidad Pontificia Comillas de Madrid, Spain, in 2010. He is currently a Research Associate Professor and the Secretary General of the Instituto de Investigación Tecnológica (IIT), Universidad Pontificia Comillas, Madrid. He has been involved in a large number of research projects related to power system operation, stability, control, and protection in low-inertia power

systems. His research interests include modeling, analysis, control of power systems, and modeling and optimization of energy systems.



Federico Milano (F'16) received from the University of Genoa, Italy, the Ph.D. in Electrical Engineering in 2003. In 2013, he joined the University College Dublin, Ireland, where he is currently a full professor. He is Secretary of the IEEE Power System Dynamic Performance Committee and past Chair of the Power System Stability Controls Subcommittee, IET Fellow, IEEE PES Distinguished Lecturer, member of the PSCC Executive Board, Senior Editor of the IEEE Transactions on Power Systems, and Co-Editor in Chief of the IET Generation, Transmission

& Distribution. His research interests include power system modeling, control and stability analysis.